



**NEW HANOVER COUNTY
FINANCE DEPARTMENT, PURCHASING DIVISION
ADDENDUM 1**

From: Lena Butler, Purchasing Supervisor
To: All Bidders
Project: REBID RFB-Northern Regional Park Multiuse Path
Date: April 5, 2022

This Addendum is related to the County's Request for **"REBID RFB-Northern Regional Park Multiuse Path"** and is hereby made a part of said Request for Bids to the same extent as though it were originally therein.

Question 1- Is there anyway that the Pre-Bid Qualification can be extended until 3-31-22?

Yes, we will extend the date until Friday, April 1, 2022.

Question 2- The plans call for 12" excelsior barrier wattle, will 12" Excelsior Filtrex sock be acceptable?

Answer – Yes, the filtrex sock is acceptable.

Question 3- The plans call for Jute Lining in the new 5:1 V-shaped ditch, will Excelsior matting be acceptable?

Answer – Yes, Excelsior matting is acceptable.