

RFB 22-0574 Elevator Maintenance Services - Questions and Answers

Questions and Answers:

1. Do you have a list of when the last 5yr tests were completed on each of the traction elevators? Some of the elevators in the judicial building didn't have 5yr tags on them.

A –

New Hanover County Elevator Testing Schedule	
Location	CAT 5
320 Chestnut #1	Last Tagged Oct-2015 (TKE)
320 Chestnut #2	Last Tagged Oct-2015 (TKE)
Bellsouth Building	N/A
Cape Fear Museum Freight	N/A
Cape Fear Museum Passenger	N/A
Detention Center	N/A
HHS #1	Initial test on 10/8/2019
HHS #2	Initial test on 10/8/2019
Wrightsboro Fire	N/A
Historic Courthouse	N/A
Judicial #1	8/24/2017
Judicial #2	8/24/2017
Judicial #3	8/24/2017
Judicial #4	8/24/2017
Judicial #5	8/24/2017
Judicial #6	N/A
Judicial #7	N/A
Judicial #8	N/A
Judicial #9	N/A

Judicial #10	N/A
Judicial Dumbwaiter	N/A
Juvenile Justice #1	Initial test/inspection on 1/7/2021
Juvenile Justice #2	Initial test/inspection on 1/7/2021
Juvenile Justice #3	Initial test/inspection on 1/7/2021
Downtown Library Passenger	Last Tagged 7-16-2020 (Charter)
Downtown Library Dumbwaiter	N/A
Library Parking Deck #1	DUE
Library Parking Deck #2	DUE

2. Will the winning vendor be responsible for 5-year load test? You have several modernized traction elevators with no 5-year tags, they should be scheduled for this year.

A – Please see above.